

CA-NV AWWA Water Loss Technical Assistance Program

Wave 4 Water Audit Level 1 Validation Document

Audit Information:

Utility: Bellflower-Somerset Mutual Water company **PWS ID:** 1910019
System Type: Potable **Audit Period:** Calendar 2018
Utility Representation: Steve Lenton (General manager)
Validation Date: 6/7/2019 **Call Time:** 10am **Sufficient Supporting Documents Provided:** Yes

Validation Findings & Confirmation Statement:

Key Audit Metrics:

Data Validity Score: 69 **Data Validity Band (Level):** Band III (51-70)
ILI: 1.47 **Real Loss:** 16.52 (gal/conn/day) **Apparent Loss:** 0.61 (gal/conn/day)
Non-revenue water as percent of cost of operating system: 0.3%

Certification Statement by Validator:

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. ☑

Validator Information:

Water Audit Validator: Tanmay Thakur **Validator Qualifications:** Water Audit Validator Certificate issued by the CA-NV Section of the AWWA

Validator Provided